

保護等級	LEVEL I r=20					LEVEL II r=30					LEVEL III r=45					LEVEL IV r=60				
	PDC6.4 (60us)	PDC6.3 (54us)	PDC3.4 (40us)	PDC3.3 (30us)	PDC3.1 (15us)	PDC6.4 (60us)	PDC6.3 (54us)	PDC3.4 (40us)	PDC3.3 (30us)	PDC3.1 (15us)	PDC6.4 (60us)	PDC6.3 (54us)	PDC3.4 (40us)	PDC3.3 (30us)	PDC3.1 (15us)	PDC6.4 (60us)	PDC6.3 (54us)	PDC3.4 (40us)	PDC3.3 (30us)	PDC3.1 (15us)
避雷針型式	Rp(h) Radius of protection 有效保護半徑(m)										Rp(h) Radius of protection 有效保護半徑(m)									
h(m)	Rp(h) Radius of protection 有效保護半徑(m)										Rp(h) Radius of protection 有效保護半徑(m)									
2	31	29	23	19	12	34	32	26	21	14	38	36	30	25	17	42	40	33	28	20
4	62	58	46	38	25	69	64	52	43	29	77	72	60	50	35	85	80	66	57	40
5	78	72	58	47	31	86	80	65	54	37	97	90	75	63	44	106	99	83	71	51
6	78	73	58	48	32	86	80	65	54	38	97	91	75	64	45	107	100	84	72	52
8	79	73	59	48	32	87	81	66	55	39	98	91	76	65	47	108	101	85	73	54
10	79	73	59	49	33	87	82	66	56	40	98	93	77	66	48	109	102	86	74	55
15	79	73	59	49	34	88	82	68	58	42	100	94	79	68	51	111	104	89	78	60
20	80	74	60	50	35	89	83	69	59	43	101	95	81	70	54	113	106	91	80	63
25	79	73	59	49	34	89	83	69	59	44	103	96	82	72	56	114	108	93	83	65
30	79	73	59	49	33	90	84	70	60	45	103	97	83	73	58	116	109	95	85	68
45	75	69	54	43	24	88	82	68	58	42	105	99	85	75	60	119	113	98	88	73
60	69	62	44	30	*	84	78	63	51	33	103	97	83	73	58	120	114	100	90	75

註1:本表依據109年5月27日內授營建管字第1090808873號函會議記錄更新。

註2:本表數據為廠商建議值。

註3:有關高層建築物應按建築技術規則建築設計施工篇第253條規定就個案檢討考慮雷電測及對應措施。

註4:依107年9月21日內授營建管字第1070815634號函:計算結果取保守值,統一採無條件捨去至整數位。